



A P P R O V A L S ®

Certificate of Suitability

* Addendum *

Certificate No.: SAA162252

Date of Issue: 19 October 2016

Class Description: Non-Declared

Product Description: Grid-tied Inverter

Additional Models

Description

URE-1P3.6K-4G	Input: 600Vdc Max, MPP range 100-500Vdc 2x11A Isc 2x17.2A Output: 230/240V~ 50Hz 16A 4000VA
URE-1P4K-4G	Input: 600Vdc Max, MPP range 100-500Vdc 2x11A Isc 2x17.2A Output: 230/240V~ 50Hz 21A 4400VA
URE-1P4.6K-4G	Input: 600Vdc Max, MPP range 100-500Vdc 2x11A Isc 2x17.2A Output: 230/240V~ 50Hz 21.7A 5000VA
URE-1P5K-4G	Input: 600Vdc Max, MPP range 100-500Vdc 2x11A Isc 2x17.2A Output: 230/240V~ 50Hz 21.7A 5000VA
Mate-1K-ST	Input: 550Vdc Max, MPP range 50-450Vdc 11A Isc 17.2A Output: 230/240V~ 50Hz 5.2A 1100VA
Mate-1.5K-ST	Input: 550Vdc Max, MPP range 50-450Vdc 11A Isc 17.2A Output: 230/240V~ 50Hz 8.1A 1700VA
Mate-2K-ST	Input: 550Vdc Max, MPP range 50-450Vdc 11A Isc 17.2A Output: 230/240V~ 50Hz 10.5A 2200VA
Mate-2.5K-ST	Input: 550Vdc Max, MPP range 50-450Vdc 11A Isc 17.2A Output: 230/240V~ 50Hz 13.3A 2800VA
Mate-3K-ST	Input: 600Vdc Max, MPP range 100-500Vdc 11A Isc 17.2A Output: 230/240V~ 50Hz 15.7A 3300VA
Mate-3K-MT	Input: 600Vdc Max, MPP range 100-500Vdc 2x11A Isc 2x17.2A Output: 230/240V~ 50Hz 15.7A 3300VA
Mate-3.6K-MT	Input: 600Vdc Max, MPP range 100-500Vdc 2x11A Isc 2x17.2A Output: 230/240V~ 50Hz 16A 4000VA

For and on Behalf of
SAA Approvals Pty Ltd

SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:
www.saaapprovals.com.au

JAS-ANZ



www.jas-anz.org/register



Issued: 20-10-16 162252/6a
Certificate information amended