



A P P R O V A L S ®

Certificate of Suitability

* Addendum *

Certificate No.: SAA162252

Date of Issue: 19 October 2016

Class Description: Non-Declared

Product Description: Grid-tied Inverter

| Additional Models | Description |
|--------------------------|--|
| Mate-4K-MT | Input: 600Vdc Max, MPP range 100-500Vdc 2x11A Isc 2x17.2A Output: 230/240V~ 50Hz 21A 4400VA |
| Mate-4.6K-MT | Input: 600Vdc Max, MPP range 100-500Vdc 2x11A Isc 2x17.2A Output: 230/240V~ 50Hz 21.7A 5000VA |
| Mate-5K-MT | Input: 600Vdc Max, MPP range 100-500Vdc 2x11A Isc 2x17.2A Output: 230/240V~ 50Hz 21.7A 5000VA |

For and on Behalf of
SAA Approvals Pty Ltd

SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:
www.saaapprovals.com.au

JAS-ANZ



www.jas-anz.org/register



Issued: 20-10-16 162252/7a
Certificate information amended