



A P P R O V A L S ®

## Certificate of Suitability

\* Addendum \*

**Certificate No.:** SAA180763

**Date of Issue:** 20 March 2018

**Class Description:** Non-Declared

**Product Description:** Grid-tied Inverter

Additional Models	Description
Solis-50K-HV	Input: 1100Vdc Max, Mpp voltage 200-1000Vdc, Max 4x22A $I_{sc}$ PV 4x34.3A Output: 277/480V ~ 3N/PE 50/60Hz 66.2A Max 55000VA Max
Solis-50K	Input: 1100Vdc Max, Mpp voltage 200-1000Vdc, Max 4x28.5A, $I_{sc}$ PV 4x44.5A Output: 230/400V ~ 3N/PE 50/60Hz 83.3A Max 55000VA Max
Solis-40K	Input: 1100Vdc Max, Mpp voltage 200-1000Vdc, Max 4x22A, $I_{sc}$ PV 4x34.3A Output: 230/400V ~ 3N/PE 50/60Hz 66.9A Max 44000VA Max
Solapowa-60K-HV	Input: 1100Vdc Max, Mpp voltage 200-1000Vdc, Max 4x28.5A, $I_{sc}$ PV 4x44.5A Output: 277/480V ~ 3/PE 50/60Hz 80A Max 66000VA Max
Solapowa-50K-HV	Input: 1100Vdc Max, Mpp voltage 200-1000Vdc, Max 4x22A, $I_{sc}$ PV 4x34.3A Output: 277/480V ~ 3/PE 50/60Hz 66.2A Max 55000VA Max
Solapowa-50K	Input: 1100Vdc Max, Mpp voltage 200-1000Vdc, Max 4x28.5A, $I_{sc}$ PV 4x44.5A Output: 230/400V ~ 3N/PE 50/60Hz 83.3A Max 55000VA Max
Solapowa-40K	Input: 1100Vdc Max, Mpp voltage 200-1000Vdc, Max 4x22A, $I_{sc}$ PV 4x34.3A Output: 230/400V ~ 3N/PE 50/60Hz 66.9A Max 44000VA Max


For and on Behalf of  
SAA Approvals Pty Ltd

SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:  
[www.saaapprovals.com.au](http://www.saaapprovals.com.au)

JAS-ANZ



[www.jas-anz.org/register](http://www.jas-anz.org/register)



Issued: 22-03-18 180763/2a  
Correction to Descriptions