



A P P R O V A L S ®

Certificate of Suitability

* Addendum *

Certificate No.: SAA180763

Date of Issue: 20 March 2018

Class Description: Non-Declared

Product Description: Grid-tied Inverter

Additional Models	Description
Soltaro-60K-HV	Input: 1100Vdc Max, Mpp voltage 200-1000Vdc, Max 4x28.5A, I_{sc} PV 4x44.5A Output: 277/480V ~ 3/PE 50/60Hz 80A Max 66000VA Max
Soltaro-50K-HV	Input: 1100Vdc Max, Mpp voltage 200-1000Vdc, Max 4x22A, I_{sc} PV 4x34.3A Output: 277/480V ~ 3/PE 50/60Hz 66.2A Max 55000VA Max
Soltaro-50K	Input: 1100Vdc Max, Mpp voltage 200-1000Vdc, Max 4x28.5A, I_{sc} PV 4x44.5A Output: 230/400V ~ 3N/PE 50/60Hz 83.3A Max 55000VA Max
Soltaro-40K	Input: 1100Vdc Max, Mpp voltage 200-1000Vdc, Max 4x22A, I_{sc} PV 4x34.3A Output: 230/400V ~ 3N/PE 50/60Hz 66.9A Max 44000VA Max
URE-50K	Input: 1100Vdc Max, Mpp voltage 200-1000Vdc, Max 4x28.5A, I_{sc} PV 4x44.5A Output: 230/400V ~ 3N/PE 50/60Hz 83.3A Max 55000VA Max
URE-40K	Input: 1100Vdc Max, Mpp voltage 200-1000Vdc, Max 4x22A, I_{sc} PV 4x34.3A Output: 230/400V ~ 3N/PE 50/60Hz 66.9A Max 44000VA Max


For and on Behalf of
SAA Approvals Pty Ltd

SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:
www.saaapprovals.com.au

JAS-ANZ



www.jas-anz.org/register



Issued: 20-03-18 180763/3