



A P P R O V A L S ®

## Certificate of Suitability

\* Addendum \*

**Certificate No.:** SAA182159

**Date of Issue:** 1 August 2018

**Class Description:** Non-Declared

**Product Description:** Hybrid Inverter

<b>Additional Models</b>	<b>Description</b>
RHI-4.6K-48ES	Input: 600Vdc Max, MPP voltage range 90-520Vdc 2x11A Isc PV 2x17.2A Grid Input: 230V~ 50Hz 23.9A Grid output: 230V~ 50Hz 21.7A 4600VA Back-up output: 230V~ 50Hz 13A 3000VA Battery: 42-58Vdc charge/discharge 62.5/62.5A
RHI-3.6K-48ES	Input: 600Vdc Max, MPP voltage range 90-520Vdc 2x11A Isc PV 2x17.2A Grid Input: 230V~ 50Hz 23.9A Grid output: 230V~ 50Hz 17.3A 4000VA Back-up output: 230V~ 50Hz 13A 3000VA Battery: 42-58Vdc charge/discharge 62.5/62.5A
RHI-3K-48ES	Input: 600Vdc Max, MPP voltage range 90-520Vdc 2x11A Isc PV 2x17.2A Grid Input: 230V~ 50Hz 23.9A Grid output: 230V~ 50Hz 15.7A 3300VA Back-up output: 230V~ 50Hz 13A 3000VA Battery: 42-58Vdc charge/discharge 62.5/62.5A

For and on Behalf of  
SAA Approvals Pty Ltd

SAA Approvals Pty Ltd certifies that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:  
[www.saaapprovals.com.au](http://www.saaapprovals.com.au)



Issued: 01-08-18 182159/2