



Attestation of Conformity

No. N8A 086470 0030 Rev. 02

Holder of Certificate: Ginlong Technologies Co., Ltd.

No.57 Jintong Road

Binhai Industrial Park, Xiangshan 315712 Ningbo, Zhejiang PEOPLE'S REPUBLIC OF CHINA

Product: Converter

Grid-Tied Inverter

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2014/35/EU relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for testing and certification. For details see: www.tuvsud.com/ps-cert

Test report no.: 704091716002-04

Date, 2022-11-14

(Zhengdong Ma)



After preparation of the necessary technical documentation as well as the EU declaration of conformity the required CE marking can be affixed on the product. The declaration of conformity is issued under the sole responsibility of the manufacturer. Other relevant EU-directives have to be observed.







Attestation of Conformity

No. N8A 086470 0030 Rev. 02

Model(s): Solis-25K-LV, Solis-30K-LV, Solis-40K, Solis-50K, Solis-50K-HV, Solis-60K-HV,

Solis-60K-4G

Parameters:

| See electrical ratings for various models |
|---|
| See electrical ratings for various models |
| See electrical ratings for various models |
| See electrical ratings for various models |
| |
| See electrical ratings for various models |
| 50/60Hz |
| See electrical ratings for various models |
| See electrical ratings for various models |
| See electrical ratings for various models |
| -0.81+0.8 |
| I |
| IP65 |
| II(PV), III(MAINS) |
| -25 +60°C |
| |

Electrical ratings for various models:

| Models | Solis-25K-LV | Solis-30K-LV | Solis-40K | Solis-50K | | |
|----------------------------|---------------|---------------|---------------------|---------------------|--|--|
| PV input ratigns | | | | | | |
| Max. input voltage: | d.c. 1100 V | d.c. 1100 V | d.c. 1100 V | d.c. 1100 V | | |
| MPP voltage range: | d.c. 200-850V | d.c. 200-850V | d.c. 200- 1000V | d.c. 200- 1000V | | |
| Max. input current: | d.c. 2×28.5A | d.c. 2×28.5A | d.c. 4×22A | d.c. 4×28.5A | | |
| Isc PV (absolute maximum): | d.c. 2×44.5A | d.c. 2×44.5A | d.c. 4×34.3A | d.c. 4×44.5A | | |
| AC output ratigns | | | | | | |
| Rated grid voltage: | 3/PE~ 220V | 3/PE~ 220V | 3/N/PE~ 230/400V | 3/N/PE~ 230/400V | | |
| Rated grid frequency: | 50/60Hz | | | | | |

Page 2 of 3

After preparation of the necessary technical documentation as well as the EU declaration of conformity the required CE marking can be affixed on the product. The declaration of conformity is issued under the sole responsibility of the manufacturer. Other relevant EU-directives have to be observed.







Attestation of Conformity

No. N8A 086470 0030 Rev. 02

| Max. AC output active power: | 25000W | 30000W | 44000W | 55000W |
|---------------------------------|-------------|-------------|-------------|-------------|
| Max. AC output apparent power: | 25000VA | 30000VA | 44000VA | 55000VA |
| Max. Continuous output current: | a.c. 65.6 A | a.c. 78.8 A | a.c. 66.9 A | a.c. 83.3 A |

| Models | Solis-50K-HV | Solis-60K-HV | Solis-60K-4G | | | |
|---------------------------------|----------------|----------------|------------------|--|--|--|
| PV input ratigns | | | | | | |
| Max. input voltage: | d.c. 1100 V | d.c. 1100 V | d.c. 1100 V | | | |
| MPP voltage range: | d.c. 200-1000V | d.c. 200-1000V | d.c. 200-1000V | | | |
| Max. input current: | d.c. 4×22A | d.c. 4×28.5A | d.c. 4×28.5A | | | |
| Isc PV (absolute maximum): | d.c. 4×34.3A | d.c. 4×44.5A | d.c. 4×44.5A | | | |
| AC output ratigns | | | | | | |
| Rated grid voltage: | 3/PE~ 480V | 3/PE~ 480V | 3/N/PE~ 230/400V | | | |
| Rated grid frequency: | 50/60Hz | | | | | |
| Max. AC output active power: | 55000W | 66000W | 66000W | | | |
| Max. AC output apparent power: | 55000VA | 66000VA | 66000VA | | | |
| Max. Continuous output current: | a.c. 66.2 A | a.c. 80 A | a.c. 100 A | | | |

Tested EN 62109-1:2010 EN 62109-2:2011

Page 3 of 3

After preparation of the necessary technical documentation as well as the EU declaration of conformity the required CE marking can be affixed on the product. The declaration of conformity is issued under the sole responsibility of the manufacturer. Other relevant EU-directives have to be observed.

