

Ginlong technologies Co., Ltd.
Qingying Cui

Date : 17.01.2023
Our ref. : Jiangyi 01
Your ref.: Qingying Cui

No.57 Jintong Road, Binhai,
(seafront), Industrial Park,
Xiangshan Ningbo
315712 Zhejiang
P.R. China

Ref : R TÜV-Bauart-Zeichen o. Akkred. Nr.

Type of Equipment : Grid-connected PV Inverter
Model Designation : See Certificate
Certificate No. : R 50571748 0001
Report No. : CN22LOGH 001

Dear Qingying Cui,

The above specified equipment has been tested and found to be in accordance with the relevant requirements.

Please find enclosed your certificate as specified above.

If cancellation of the certificate is submitted by 15 November in a given year, no fee will be charged for the following year.

The certificate is issued with the reservation that the license holder applies all information required in § 6 of the ProdSG related to name and address of the manufacturer or his authorized representative / importer, including their respective contact addresses on the product prior to marketing of the product in the European Economic Area. In case you have a change regarding your involved local representative for the certificate, please inform us in due time.

With kind regards,

Certification Body

Weichun Li

Enclosure

证书的详细资料请登陆www.certipedia.com查阅,或拨打我司客服热线800 999 3668 / 400 883 1300咨询

Zertifikat

Certificate



Zertifikat Nr. Certificate No.
R 50571748

Blatt Sheet
0001

Ihr Zeichen Client Reference
Qingying Cui

Unser Zeichen Our Reference
01-Jiangyi-CN22LOGH 001

Ausstellungsdatum
17.01.2023

Date of Issue
(day/mo/yr)

Genehmigungsinhaber License Holder

Ginlong technologies Co., Ltd.
No.57 Jintong Road, Binhai,
(seafront), Industrial Park,
Xiangshan Ningbo
315712 Zhejiang
P.R. China

Fertigungsstätte Manufacturing Plant

Ginlong technologies Co., Ltd.
No. 188 Jinkai Road, Binhai Industrial
Park, Xiangshan, Ningbo,
315712 Zhejiang
P.R. China

Prüfzeichen Test Mark



Bauart geprüft
Sicherheit
Regelmäßige
Produktions-
überwachung

www.tuv.com
ID 1111263882

Geprüft nach Tested acc. to

IEC 62109-1:2010
IEC 62109-2:2011
EN 62109-1:2010
EN 62109-2:2011

Zertifiziertes Produkt (Geräteidentifikation)
Certified Product (Product Identification)

Lizenzentgelte - Einheit
License Fee - Unit

PV-Wechselrichter (Grid-connected PV Inverter)

Type Designation	: Solis-75K-5G-PRO Solis-80K-5G-PRO	11
Isc PV [Ad.c.]	: 50*6	
Vmax PV [Vd.c.]	: 1100	
Max. Input Current Ad.c.]	: 36*3+32*3	
MPP Voltage Range [Vd.c.]	: 160-1000	
Overvoltage Category (OVC)	: II for PV	
Rated Output Volt. [Va.c.]	: 3/N/PE, 220/380 3/N/PE, 220/380, 230/400	
Rated Output Freq. [Hz]	: 50 50/60	
Max. Output Curr. [Aa.c.]	: 114 133.7	
Rated Output Power [kW]	: 75 80	
Power Factor	: >0.99 [-0.8 to 0.8]	
Overvoltage Category (OVC)	: III for AC mains	

continued on page 0002

11

ANLAGE (Appendix): 1.0

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde und es bestätigt die Konformität des Produktes mit den oben genannten Standards und Prüfgrundlagen. Zusätzliche Anforderungen in Ländern, in denen das Produkt in Verkehr gebracht werden soll, müssen zusätzlich betrachtet werden. Die Herstellung des zertifizierten Produktes wird überwacht.
This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance.



Zertifizierungsstelle

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg

http://www.tuv.com/safety E-mail: markcheck@tuv.com
Fax: +49 221 806-3935

Weichun Li

Zertifikat

Certificate



Zertifikat Nr. Certificate No.
R 50571748

Blatt Sheet
0002

Ihr Zeichen Client Reference
Qingying Cui

Unser Zeichen Our Reference
01-Jiangyi-CN22LOGH 001

Ausstellungsdatum
17.01.2023

Date of Issue
(day/mo/yr)

Genehmigungsinhaber License Holder

Ginlong technologies Co., Ltd.
No.57 Jintong Road, Binhai,
(seafront), Industrial Park,
Xiangshan Ningbo
315712 Zhejiang
P.R. China

Fertigungsstätte Manufacturing Plant

Ginlong technologies Co., Ltd.
No. 188 Jinkai Road, Binhai Industrial
Park, Xiangshan, Ningbo,
315712 Zhejiang
P.R. China

Prüfzeichen Test Mark



Bauart geprüft
Sicherheit
Regelmäßige
Produktions-
überwachung

www.tuv.com
ID 1111263882

Geprüft nach Tested acc. to

IEC 62109-1:2010
IEC 62109-2:2011
EN 62109-1:2010
EN 62109-2:2011

Zertifiziertes Produkt (Geräteidentifikation)
Certified Product (Product Identification)

Lizenzentgelte - Einheit
License Fee - Unit

PV-Wechselrichter (Grid-connected PV Inverter)

as page 0001 continuation
Type Designation

: Solis-100K-5G-PRO
Solis-110K-5G-PRO

Isc PV [Ad.c.] : 50*8
Vmax PV [Vd.c.] : 1100

Max. Input Current Ad.c.] : 36*4+32*4
MPP Voltage Range [Vd.c.] : 160-1000
Overvoltage Category (OVC) : II for PV

Rated Output Volt. [Va.c.] : 3/N/PE, 220/380, 230/400
Rated Output Freq. [Hz] : 50/60
Max. Output Curr. [Aa.c.] : 167.1 183.8
Rated Output Power [kW] : 100 110
Power Factor : >0.99 [-0.8 to 0.8]
Overvoltage Category (OVC) : III for AC mains

continued on page 0003

2

2

ANLAGE (Appendix) : 1.0

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde und es bestätigt die Konformität des Produktes mit den oben genannten Standards und Prüfgrundlagen. Zusätzliche Anforderungen in Ländern, in denen das Produkt in Verkehr gebracht werden soll, müssen zusätzlich betrachtet werden. Die Herstellung des zertifizierten Produktes wird überwacht.
This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance.



Zertifizierungsstelle

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg

http://www.tuv.com/safety E-mail: markcheck@tuv.com
Fax: +49 221 806-3935

Weichun Li

Zertifikat

Certificate



Zertifikat Nr. Certificate No.
R 50571748

Blatt Sheet
0003

Ihr Zeichen Client Reference
Qingying Cui

Unser Zeichen Our Reference
01-Jiangyi-CN22LOGH 001

Ausstellungsdatum
17.01.2023

Date of Issue
(day/mo/yr)

Genehmigungsinhaber License Holder

Ginlong technologies Co., Ltd.
No.57 Jintong Road, Binhai,
(seafront), Industrial Park,
Xiangshan Ningbo
315712 Zhejiang
P.R. China

Fertigungsstätte Manufacturing Plant

Ginlong technologies Co., Ltd.
No. 188 Jinkai Road, Binhai Industrial
Park, Xiangshan, Ningbo,
315712 Zhejiang
P.R. China

Prüfzeichen Test Mark



Bauart geprüft
Sicherheit
Regelmäßige
Produktions-
überwachung

www.tuv.com
ID 1111263882

Geprüft nach Tested acc. to

IEC 62109-1:2010
IEC 62109-2:2011
EN 62109-1:2010
EN 62109-2:2011

Zertifiziertes Produkt (Geräteidentifikation)
Certified Product (Product Identification)

Lizenzentgelte - Einheit
License Fee - Unit

PV-Wechselrichter (Grid-connected PV Inverter)

as page 0002 continuation
Type Designation

: Solis-120K-5G-PRO
Solis-125K-5G-PRO

Isc PV [Ad.c.] : 50*10
Vmax PV [Vd.c.] : 1100

Max. Input Current Ad.c.] : 36*4+32*6
MPP Voltage Range [Vd.c.] : 160-1000
Overvoltage Category (OVC) : II for PV

Rated Output Volt. [Va.c.] : 3/N/PE, 220/380
3/N/PE, 220/380, 230/400

Rated Output Freq. [Hz] : 50/60
Max. Output Curr. [Aa.c.] : 200.6 198.5
Rated Output Power [kW] : 120 125
Power Factor : >0.99 [-0.8 to 0.8]
Overvoltage Category (OVC) : III for AC mains

continued on page 0004

2

2

ANLAGE (Appendix) : 1.0

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde und es bestätigt die Konformität des Produktes mit den oben genannten Standards und Prüfgrundlagen. Zusätzliche Anforderungen in Ländern, in denen das Produkt in Verkehr gebracht werden soll, müssen zusätzlich betrachtet werden. Die Herstellung des zertifizierten Produktes wird überwacht.
This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance.

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg

http://www.tuv.com/safety E-mail: markcheck@tuv.com
Fax: +49 221 806-3935



Zertifizierungsstelle

Weichun Li

Zertifikat

Certificate



Zertifikat Nr. Certificate No.
R 50571748

Blatt Sheet
0004

Ihr Zeichen Client Reference
Qingying Cui

Unser Zeichen Our Reference
01-Jiangyi-CN22LOGH 001

Ausstellungsdatum
17.01.2023

Date of Issue
(day/mo/yr)

Genehmigungsinhaber License Holder

Ginlong technologies Co., Ltd.
No.57 Jintong Road, Binhai,
(seafront), Industrial Park,
Xiangshan Ningbo
315712 Zhejiang
P.R. China

Fertigungsstätte Manufacturing Plant

Ginlong technologies Co., Ltd.
No. 188 Jinkai Road, Binhai Industrial
Park, Xiangshan, Ningbo,
315712 Zhejiang
P.R. China

Prüfzeichen Test Mark



Bauart geprüft
Sicherheit
Regelmäßige
Produktions-
überwachung

www.tuv.com
ID 1111263882

Geprüft nach Tested acc. to

IEC 62109-1:2010
IEC 62109-2:2011
EN 62109-1:2010
EN 62109-2:2011

Zertifiziertes Produkt (Geräteidentifikation)
Certified Product (Product Identification)

Lizenzentgelte - Einheit
License Fee - Unit

PV-Wechselrichter (Grid-connected PV Inverter)

as page 0003 continuation

Protective Class : I
Enclosure Protection (IP) : IP66
Pollution degree (PD) : PD2 (inside), PD3 (outside)
Altitude [m] : 4000
Operating Temperature [°C] : -30 to 60 (>45 derating)
Type of Inverter : Non-isolated

Remark:

The installation has to be carried out according to the attached installation instruction.
Any additional requirements in countries where the product is going to be marketed have to be considered additionally.

ANLAGE (Appendix): 1.0

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde und es bestätigt die Konformität des Produktes mit den oben genannten Standards und Prüfgrundlagen. Zusätzliche Anforderungen in Ländern, in denen das Produkt in Verkehr gebracht werden soll, müssen zusätzlich betrachtet werden. Die Herstellung des zertifizierten Produktes wird überwacht.
This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance.



Zertifizierungsstelle

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg

http://www.tuv.com/safety E-mail: markcheck@tuv.com
Fax: +49 221 806-3935

Weichun Li